

OFFICE OF THE DISTRICT MEDICAL AND HEALTH OFFICER  
HANMAKONDA

SANITARY & NO OBJECTION CERTIFICATE  
(Appendix 11 Rules Chapter – 8)



R.C.No.124/Epidemic/2025.

Date: 24-03-2025

Hereby declare that I have inspected the name "TALLA PADMAVATHI SCHOOL" Building bearing Municipal situated at HNo-64-4-2, Tekulagudem(Somidi),Kazipet,Hanamkonda District. Certify that the accommodation provided for each of the several classes is sufficient for the maximum number of pupils taught. The building is properly ventilated and lighted. The building is maintained in substantial repair that is neat clean. The Toilet facilities are adequate and satisfactory. The supply of drinking water is whole some and that all other necessary sanitation requirements are good for the year 2025-26

  
District Medical & Health Officer  
Hanamakonda.  
24/03/25

  
Master  
TALLA PADMAVATHI SCHOOL  
Tekulagudem (Somidi), Kazipet.  
WARANGAL

  
Secretary & Correspondent  
TALLA PADMAVATHI SCHOOL  
Tekulagudem (Somidi), Kazipet,  
HANAMKONDA (Dist.)



# INDUSTRIAL CONSULTANCY CELL

(Member of Consultancy Development Centre, Supported by DSIR, Ministry of Science & Technology, New Delhi)

Address : Kakatiya Institute of Technology & Science Campus  
(Autonomous)

Opp: Yerragattu Hillock, Vill: Bheemaram, Mdl: Hasanparthy, Warangal - 506 015 TELANGANA  
Phone : 0870 - 2564322, 2564888

2024 046

No. ICC/CED/Water/CW-2425-014/

Date: 28.06.2024

To,  
Secretary & Correspondent,  
Talla Padmavathi School  
Tekulagudem (Somidi),  
Kazipet, Hanamkonda

Sir,

Sub: Water Analysis report -testing of water for Drinking Purpose - Reg.  
Ref: Your Lr.No TPOS/010/2024, Dated: 27.06.2024

\*\*\*

With reference to the subject cited under reference, the water sample which was received at our laboratory by your representative and the results of which are given below:

Sl. No.	Constituents	Result For Sample	Limits / Range for Drinking Purpose
1	pH Value	6.62	6.5 to 8.5
2	Odour	Agreeable	Satisfactory
3	Colour	Colourless	Satisfactory
4	Conductivity	90.0 $\mu$ mhos/cm	1500 $\mu$ mhos/cm
5	Total dissolved solids	60 mg/L	500mg/L - Drinking
6	Total hardness	90 ppm	Less than- 500 ppm
7	Chlorides	70.9 mg/L	Less than 600 mg/L
8	Total alkalinity Methyl orange	122 mg / L	Less than 500ppm
9	Degree of hardness	90 CaCO <sub>3</sub> Eq.	Less than 500 CaCO <sub>3</sub> Eq.
10	Hardness as Ca	40 ppm	100.00 ppm
11	Hardness as Mg	50 ppm	60.00 ppm
12	Suspended solids	Nil	500mg/L - Drinking
13	Nature of the water	Neutral	Neutral - pH=7

Note: As per the above tests conducted the water sample suitable for drinking purpose.

  
(Dr. D. Prabhakara Chary)  
Consultant  
Head Master  
TALLA PADMAVATHI SCHOOL  
Tekulagudem (Somidi), Kazipet.  
WARANGAL

  
(Dr. S. Sunil Pratap Reddy)  
Coordinator

  
PRINCIPAL

Principal  
KAKATIYA INSTITUTE OF TECHNOLOGY & SCIENCE  
Opp: Yerragattugutta, Vill: Bheemaram,  
Hanamkonda, Warangal-506015. (TS)

Page 1 of 1

Secretary & Correspondent  
TALLA PADMAVATHI SCHOOL  
Tekulagudem (Somidi), Kazipet,  
HANAMKONDA (Dist.)



# INDUSTRIAL CONSULTANCY CELL

(Member of Consultancy Development Centre, Supported by DSIR, Ministry of Science & Technology, New Delhi)

Address : Kakatiya Institute of Technology & Science Campus  
(Autonomous)

Opp: Yerragattu Hillock, Vill: Bheemaram, Md: Hasanparthy, Warangal - 506 016 TELANGANA  
Phone : 0870 - 2564322, 2564888

2024

048


## SAFE DRINKING WATER CERTIFICATE

Dated: 28.06.2024

No. ICC/CED/Water/CW-2425-014

It is certified that an inspection team headed by Dr. S. Sunil Pratap Reddy, Coordinator ICC and Dr. D. Prabhakara Chary, Assoc. Professor of Chemistry, from Dept. of Civil Engineering & Physical Sciences, KITSW inspected the Talla Padmavathi School, Tekulagudem Road, Somidi, Kazipet, Dist. Hanamkonda on 27.06.2024 and found that the Talla Padmavathi School has Safe drinking water facilities for the students and members of staff of the institution in the school building & the campus as per norms prescribed by the Central/State U.T Govt.

The above is valid for a period of Two years.

Signature with Seal:   
Name: Dr. K. Ashoka Reddy

Designation: Principal,

Name & Address of the Office /Department:

Kakatiya Institute of Technology & Science, Warangal



To

Talla Padmavathi School  
Tekulagudem (Somidi),  
Kazipet, Hanamkonda

  
Head Master

TALLA PADMAVATHI SCHOOL  
Tekulagudem (Somidi), Kazipet  
WARANGAL

  
Secretary & Correspondent  
TALLA PADMAVATHI SCHOOL  
Tekulagudem (Somidi), Kazipet,  
HANAMKONDA (Dist.)